

CERTIFICATE

Issued to:
Applicant:
TERRA PRODUKTION GmbH
Emmerstedter Str. 20
38350 Helmstedt, Germany

Licensee:
TERRA PRODUKTION GmbH
Emmerstedter Str. 20
38350 Helmstedt, Germany

Product : Fixed luminaires with LED
Trade name(s) : TERRA PRODUKTION GmbH
Type(s)/model(s) : Vitria B3 (System Savitria), Vitria D3 (System DUS),
Vitria G3 (System GEALUX), Vitria L77 (System AEG 77),
Vitria M3 (System Maxos), Vitria R3 (System RIDI),
Vitria RE3 (System Regiolux) and Vitria T3 (System Trilux 7920)

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60598-1:2015 and EN 60598-2-1:1989
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2181432

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.


This certificate is issued on 2 April 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 88-103266

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Kate Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Fixed luminaires with LED
Trade name(s)	: TERRA PRODUKTION GmbH
Type(s)/model(s)	: Vitria B3 (System Savitria), Vitria D3 (System DUS), Vitria G3 (System GEALUX), Vitria L77 (System AEG 77), Vitria M3 (System Maxos), Vitria R3 (System RIDI), Vitria RE3 (System Regiolux) and Vitria T3 (System Trilux 7920)
Rated voltage	: 230 Vac
Rated frequency	: 50 Hz
Class	: I
Degree of protection	: IP40
Ambient temperature range (ta)	: 25 °C
Colour temperature	: 6500 K

Product data – type Vitria B3 (System Savitria) and Vitria M3 (System Maxos)

Rated input power : 20 W

Product data – type Vitria D3 (System DUS) and Vitria L77 (System AEG 77)

Rated input power : 60 W

Product data – type Vitria G3 (System GEALUX), Vitria RE3 (System Regiolux), Vitria R3 (System RIDI) and Vitria T3 (System Trilux 7920)

Rated input power : 40 W

TESTS**Test requirements**

EN 60598-1:2015
EN 60598-2-1:1989

Test result

The test results are laid down in DEKRA test file 340855600.

Additional information

- with certified built-in control gear
- with certified built-in LED modules as non-replaceable light source
- supply connection: connector

The list of components is laid down at test report 3408556.50.

Conclusion

The examination proved that all requirements were met.

Factory location

TERRA PRODUKTION GmbH
Emmerstedter Str. 20
38350 Helmstedt, Germany